

Sections 5-80 through 5-83 of Chapter 5 of the Victoria City Code are amended to read as follows:

## **ARTICLE VII. INTERNATIONAL PLUMBING CODE**

### **Sec. 5-80. Adoption of published code.**

There is hereby adopted by the city, for the purpose of establishing rules and regulations for the safe installation and maintenance of all plumbing equipment and systems, that certain code known as the International Plumbing Code, ~~2009~~ **2015** edition, published by the International Code Council Inc., save and except such portions as are hereinafter deleted, modified, or amended, of which a copy is on file with the City Secretary and a copy is on file with the Building and Environmental Inspection Department and the same is hereby adopted and incorporated as fully as if set out at length herein, and from the date on which this section shall take effect, the provisions thereof shall be controlling in the installation of plumbing systems therein contained within the corporate limits of the city.

### **Sec. 5-81. Definition.**

Wherever the term “Code Official” is used in the plumbing code, it shall be held to mean director, as defined in section 2-80.

### **Sec. 5-82. Deletions to published code.**

The following portions of the plumbing code are hereby deleted:

- (1) *Section 103 Department of Plumbing Inspection*
- (2) *Section 106 Permits*
- (3) *Section 108 Violations*
- (4) *Section 109 Means of Appeal*

### **Sec. 5-83. Amendments to published code.**

The following portions of the 2009 International Plumbing Code are hereby amended:

- (1) *Section 1003.3.4.1 Grease Interceptor Capacity* is amended to read as follows:

Section 1003.3.4.1 Grease Interceptor Capacity. Grease Interceptor shall have the grease retention capacity indicated by total fixture units from Table 1003.3.4.1 and in accordance with the following:

$$\text{Total DFU's} \times 7.5 \text{ GPM} \times 12 \text{ MRT} = \text{IC/g}$$

Where:

1003.3.4.1 DFU's = Drainage Fixture Units as indicated by footnote (b) in Table

GPM = Flow rate of Gallons per minute

MRT = Minutes retention time

IC/g = Interceptor Capacity in gallons

- (2) Table 1003.3.4.1 is amended as follows:

**TABLE 1003.3.4.1  
CAPACITY OF GREASE INTERCEPTOR (a)**

<b>Description (b)</b>	<b>Fixture units each</b>
1,2, or 3 compartment sink	3
dishwasher	6
garbage grinder	4
wok-stove	4
floor drains	3
floor sinks	3

- a. Grease interceptors shall be minimum 250 gallon and maximum 2000 gallon per individual unit or by an approved engineer design.
- b. Only those fixtures in use in the food preparation/clean up area shall be counted.